



Certificate of Compliance

Certificate: 1140722 (LR 26233-13)

Master Contract: 180842

Project: 1980118

Date Issued: 2008/06/17

Issued to: Milton Roy Company
Flow Control Division
201 Ivyland Rd
Ivyland, PA 18974-0577
USA
Attention: Mr. Hans Sturm

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: A. Holbeche, P. Eng.

Authorized by: Patricia Pasemko, Operations Manager

PRODUCTS

CLASS 3218 86 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus - For Hazardous Locations-Certified to U.S. Standards

CLASS 3218 06 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus - For Hazardous Locations

Class I, Groups A, B, C, and D; Class II, Groups E, F, and G; Class III:

Class I, Groups C and D; Class II, Groups E, F, G; Class III:

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 1140722 (LR 26233-13)

Master Contract: 180842

Project: 1980118

Date Issued: 2008/06/17

Liquid level controls, Series L471, L471SC, LV471, NF265 and L971; switch contacts rated 250V max, 3A max, 100V ac max, 100W dc max resistive; relay contacts rated 24vdc, 10 A & 120Vac 10 A; Devices marked "Single Seal" are approved to 1500 psi max, 400 °F max process temperature (or 5000 psi without single seal marking)

Notes:

1. Series catalogue numbers are followed with alpha numeric suffixes to denote mechanical variations.
2. The overall hazardous location designation is governed by the rating of the outlet box (when provided).

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-M91 - General Requirements - Canadian Electrical Code, Part II

CAN/CSA-C22.2 No.14-95 - Industrial Control Equipment

CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CSA Std C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

UL Std No. 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

UL Std No. 886 - Outlet Boxes and Fittings for Use in Hazardous (Classified) Locations

ANSI/ISA 12.27.01-2003 - Requirements for Process Sealing Between Electrical Systems and Flammable or Combustible Process Fluids